

Tim Fisher

From: Chris Barth <cbarth@fire2wire.com>
Sent: Thursday, October 02, 2014 8:26 AM
To: 'Tim Fisher'
Subject: FW: Water Meters

Tim we'll need to talk about this at the board meeting. I probably not have the number of connections correct but in the ball park.

Thanks
Chris

From: Delgado, Charles@Waterboards [<mailto:Charles.Delgado@waterboards.ca.gov>]
Sent: Wednesday, October 01, 2014 1:46 PM
To: cbarth@fire2wire.com
Subject: Water Meters

Mr. Barth,

After consulting the Water Code and checking in with our technical staff, I can confirm for you that you are not required to install meters. As you operate a small system with 423 connections, you are well below the 3,000 customer/3,000 acre-feet of water supplied per year threshold at which that requirement would apply.

Please let me know if you have any other questions, or if we can help you with anything else.

Charles R. Delgado, MPPA
Assistant Legislative Director
State Water Resources Control Board
1001 I Street, Sacramento, CA
Ph. 916.341.5262
Fax 916.341.5252

No virus found in this message.

Checked by AVG - www.avg.com

Version: 10.0.1432 / Virus Database: 4031/7803 - Release Date: 10/01/14